UNIT COOLING TOWER		DWG. # T4283648-DRA-ST	REV _
MODEL# SCALE	EVAPCO, INC. Evapeo	SERIAL #	DATE: 9/20/2024
NOTES: 1. (M)- FAN MOTOR LOCATION 2. HEAVIEST SECTION IS FAN/CASING SECTION 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING GVD DENOTES GROOVED FLG DENOTES FLANGE 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS) 5. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT DRAWING 6. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT-IN [METRIC] [mm] 7. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa] 8.PAN FLUME BOX EQUALIZERS SUPPLIED BY	FACE B PLAN VIEW	FACE C	9/20/2024 FACE D
EVAPCO PAN EQUALIZER PIPING IS SUPPLIED BY OTHERS. 9.PAN EQUALIZER NIPPLE IS 11'-10 3/8" [3616] OFF EACH STEP SIDE. 2 1/8" [54] (4) 14" [350] BFW[GVD OUTLET (4) 3" [80] FPT OVERFLOW (4) 2" [50] MPT MAKE-UP (4) 3" [80] FPT DRAIN 5 1/8" [4118] 13'-7" [4140] 13'-11 1/4"	7" [178] 1'-5 1/4" [438] 2 1/8"	(4) 12" [300] BFW/GVD EQUALIZER	
[130] [4248]		FACE A	

HEAVIEST SECTION WEIGHT

13130 lbs+ [5960] kg+

NO. OF SHIPPING SECTIONS

DRAWN BY:

TRS

SHIPPING WEIGHT

72880 lbs+ [33060] kg+

OPERATING WEIGHT

111720 lbs+ [50680] kg+