UNIT **COOLING TOWER** MODEL # SCALE NTS AT 14-3G6

EVAPCO, INC. Evapco





DWG. # REV. T3040636-DRJ-ST DATE 3/13/2025 SERIAL #


## NOTES:

- 1. (M)- FAN MOTOR LOCATION
- 2. HÉAVIEST SECTION IS UPPER SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING **GVD DENOTES GROOVED** FLG DENOTES FLANGE
- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. MAKE-UP WATER PRESSURE
- 20 psi MIN [137 kPa], 50 psi MAX [344 kPa] 6. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMENDED STEEL SUPPORT DRAWING.
- 7. DIMENSIONS LISTED AS FOLLOWS: **ENGLISH FT-IN** [METRIC] [mm]









DRAWN BY: KWC SHIPPING NO. OF SHIPPING SECTIONS OPERATING HEAVIEST SECTION 1510 lbs+ [685] kg+ 2530 lbs+ [1150] kg+ 1070 lbs+ [490] kg+ WEIGHT WEIGHT WEIGHT