UNIT	COOLING TOWER	
MODEL #	AT 314-21 72	SCALE NTS

EVAPCO, INC. Evapeo


DWG. # REV. T4147224-DRA-ST DATE 3/18/2025 SERIAL #


## NOTES:

- 1. (M)- FAN MOTOR LOCATION
- 2. HÉAVIEST SECTION IS UPPER SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING **GVD DENOTES GROOVED** FLG DENOTES FLANGE PE DENOTES PLAIN END
- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. MAKE-UP WATER PRESSURE 20 psi MIN [137 kPa], 50 psi MAX [344 kPa]
- 6. 3/4" [19MM] DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT **DRAWING**
- 7. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT-IN [METRIC] [mm]









**FACE D** 

7" [ 178 ] 9'-2 1/4" [ 2800 ] -(3) 14" [350] 2" 51] 11'-10 1/2" [ 3620 ] BFW/GVD 17'-5 1/2" [ 5321 ] 11'-3 3/4' [ 3448 ] 8'-3 1/4" [ 2521 ] --(3) 3" [80] MPT MAKE-UP (3) 14" [350] 2'-2" [ 660 ] BFW/GVD 1'-5 3/8" [ 441 ] -(3) 4" [100] FPT OVERFLOW 9" [ 229 ] -(3) 4" [100] FPT DRAIN 23'-0" [ 7010 ] 4 1/8" [ 105 ] 23'-9" [ 7239 ] 71'-8" [ 21844 ] **FACE B FACE A** 

10650 lbs+ [4835] kg+